

2021 Energy Use Data
Town of Porter Municipal Buildings over 1,000 square feet

Property	Address	Primary Use Type	Gross Floor Area (square feet)	Site Energy Use Intensity (kBtu/ft ²)	Weather Normalized Source EUI (kBtu/ft ²)	% Difference from National Median Source EUI	Annual Greenhouse Gas Emissions (Metric Tons CO ₂ e)	Energy Performance Score
Town Hall	3265 Creek Rd	Office	7,216	7.6	11.3	- 90.7	2.7	100
Highway Garage	1800 Braley Rd.	Other- Public Services	15,820	28.9	N/A	- 57.8	26.9	N/A

During 2021, municipal buildings in the Town of Porter over 1,000 square feet purchased a total of 34,480 kWh of electricity, 443.5 Mcf of natural gas, and 4,149.3 Gallons of propane; emitting a total of 29.6 Metric Tons CO₂e.

Solar arrays at these properties offset 6 months of electricity at each property, and provided 9,800 kwh of electric generation net-metered into the grid. This energy is used by the Town at a later date, typically the following month.

Green text indicates building performance above National Average.

Red text indicates building performance below National Average.