

2023 Energy Use Data Town of Porter Municipal Buildings over 1,000 square feet								
Property	Address	Primary Use Type	Gross Floor Area (square feet)	Site Energy Use Intensity (kBtu/ft ²)	Weather Normalized Source EUI (kBtu/ft ²)	% Difference from National Median Source EUI	Annual Greenhouse Gas Emissions (Metric Tons CO ₂ e)	Energy Performance Score
Town Hall	3265 Creek Rd	Office	7,216	11.1	25.1	- 81.8	3.5	100
Highway Garage	1800 Braley Rd.	Other - Public Services	15,820	54.1	68.1	- 29.1	52.5	N/A

During 2023, municipal buildings in the Town of Porter over 1,000 square feet purchased a total of 31,920 kWh of electricity, 459.6 Mcf of natural gas, and 8478.2 Gallons of propane: emitting a total of 56 Metric Tons of Carbon Dioxide equivalent (MTCO₂e).

Solar arrays offset 5 months of electric usage at the Highway Garage and 7 months of electric usage at Town Hall.

Green text indicates building performance above National Average according to EPA.

Red text indicates building performance below National Average according to EPA.